

Watson Cogeneration Company

22850 South Wilmington Avenue  
P.O. Box 6203  
Carson, California 90749-6203  
Telephone (310) 816-1700



August 29, 1994

Mike Chunka  
Sonic Dry Clean, Inc.  
12170 Tech Center Drive  
Poway, CA 92064

Dear Mr. Chunka:


As you know, we asked you to clean a dirty filter that had been in operation approximately six months. After the filter was returned we sent this filter along with a brand new filter to a testing laboratory in Tennessee.

The purpose of this test was to check both the efficacy and efficiency of the cleaned filter compared to a new one. The test results were very impressive as to the ability of the cleaned filter to entrap particle sized that were measured down to 0.3 of a micron.

Based upon the favorable performance achieved with the cleaned filters, we will provide you with a complete set of 720 filters from one of our units to be cleaned by your process during our next shut down period scheduled for October of 94.

We have four co-gen plants and our intent is to having all the filters in these plants cleaned by your process.

Sincerely,

  
8/31/94

Steve Ingistov, P.E.